



SECTION "A-A"

NOTE:

1. #4 BARS @ 10" O.C.(ALL WALLS, VERT. & HORIZ.)
2. IF CLEARANCE CAN'T BE PROVIDED FROM TOP AND SIDES OF PIPE, A MODIFIED INLET MUST BE USED.
3. 6", 12" OR 18" PRECAST LIDS MAY BE USED.

DEPARTMENT OF PUBLIC WORKS
SPRINGFIELD, MO.

**RECESSED CURB OPENING
INLET**

ADOPTED:

SS-6-R