

NOTE:

1. MINIMUM OF 2' CLEARANCE TO BE MAINTAINED BETWEEN LATERAL LOCATIONS.

2. FOR SEWERS DEEPER THAN 20', A DESIGN SHALL BE SUBMITTED TO THE DEPARTMENT OF PUBLIC WORKS FOR APPROVAL.

